

Early Fire Hazard Properties (AS/NZS 1530.3) – Guidance Test

This Standard sets out a test method for the assessment of building materials and components according to:

- (a) their tendency to ignite
- (b) their tendency to propagate flame
- (c) the heat they release once ignition has occurred, and
- (d) their tendency to release smoke.

AWTA Product Testing offers a guidance version of the test to give clients an indication of the performance of their product. The guidance test is not suitable for regulatory compliance and does not replace results from the full version of the test.

Requirements: The Australian National Construction Code calls up the AS/NZS 1530.3 for products used in Class 2-9 buildings not called up in clauses 3, 4, 5 or 6 per Specification C1.10 clause 7. Insulation; fixed seating; drapery etc.

Test Code: T18BG

Sample size: 600mm x 450mm of which we would require 2 specimens.

Company name	
Company address	
Contact person	
Contact person email	
Contact person phone number	
Name of your product	
Composition of your product	
g/m ² or density	
Product Thickness	
End use of your product	

Delivery Address AWTA Product Testing Level 1, 191 Racecourse Rd, Flemington VIC 3031, Australia	Further information AWTA Product Testing Phone: (03) 9371 2400 Email: producttesting@awta.com.au
--	--

IMPORTANT NOTE: [That by submitting samples for testing YOU AGREE that the resulting testing shall be performed under our terms and conditions for testing and consulting services: www.awtaproducttesting.com.au/index.php/about/terms-and-conditions](http://www.awtaproducttesting.com.au/index.php/about/terms-and-conditions)