

Early Fire Hazard Properties (AS/NZS 1530.3)

This Standard sets out a test method for the assessment of building materials and components according to:

- (a) their tendency to ignite
- (b) their tendency to propagate flame
- (c) the heat they release once ignition has occurred, and
- (d) their tendency to release smoke.

Requirements: The Australian National Construction Code calls up the AS/NZS 1530.3 for products used in Class 2-9 buildings that are not called up in clauses 3, 4, 5 or 6 of Specification 7. Clause 7 and Table 4 detail requirements for products such as insulation; fixed seating; drapery etc.

Test Code: T18B

Sample size: 600mm x 450mm of which we would require 10 specimens. Alternatively send us 3.5 m² of fabric and we can prepare the samples here at the laboratory.

Company name	
Company address	
Contact person	
Contact person email	
Contact person phone number	
Name of your product	
Description of your product	
Composition of your product	
g/m ² or density	
Product Thickness	
End use of your product	

Delivery Address AWTA Product Testing Level 1, 191 Racecourse Rd, Flemington VIC 3031, Australia	Further information AWTA Product Testing Phone: (03) 9371 2400 Email: producttesting@awta.com.au
--	--

IMPORTANT NOTE: [That by submitting samples for testing YOU AGREE that the resulting testing shall be performed under our terms and conditions for testing and consulting services: www.awtaproducttesting.com.au/index.php/about/terms-and-conditions](http://www.awtaproducttesting.com.au/index.php/about/terms-and-conditions)